



**Strand Crown**  
**REALTORS**  
*Established 1923*

November 27, 1989

1820 Avenida Del Mundo  
 EL MIRADOR  
 Coronado, CA 92118

Attention: Building Manager

**RE: ASBESTOS DISCLOSURE**

To Whom it May Concern,

I would like to thank each building manager at Coronado Shores who took the time to respond to our request for information regarding the presence of asbestos. Your cooperation is greatly appreciated.

Some of you may be interested in the results of our survey, so I have outlined the results below for your information.


<u>Building Address</u>	<u>Reply</u>	<u>Report Available</u>	<u>Asbestos Present</u>
1710 - La Playa	NO	UNKNOWN	ASSUMED NOT PRESENT
1720 - La Sierra	NO	UNKNOWN	ASSUMED NOT PRESENT
1730 - Cabrillo	YES	YES	YES
1750 - La Princesa	NO	UNKNOWN	ASSUMED NOT PRESENT
1760 - Las Palmas	YES	YES	YES
1770 - Las Flores	YES	YES	YES
1780 - La Perla	NO	UNKNOWN	ASSUMED NOT PRESENT
1810 - Elcanto	NO	UNKNOWN	ASSUMED NOT PRESENT
1820 - El Mirador	YES	UNKNOWN	ASSUMED NOT PRESENT
1830 - El Camino	YES	YES	YES

Should any of our information not properly reflect the status of your building, please call us so we may correct our information. This information is being gathered for the health and safety of our future clientele, and it's accuracy is of utmost importance.


Thanks again and have a wonderful holiday season.


Yours truly,

Russell B. McKee, Inc.  
 dba Strand-Crown Realtors



**Russell B. McKee**  
 President





# Design For Health, Inc.

1516 W. Redwood, Suite 104  
San Diego, CA 92101  
(619) 291-1777

## BULK SAMPLE ANALYSIS REPORT

**CLIENT:** Jamie Darnell  
1780 Avenida Del Mundo  
Coronado, Ca 92118

**ANALYSIS REQUEST:** Eight bulk samples collected for analysis of asbestos material

**ANALYTICAL METHODOLOGY:** Polarized Light Microscopy/Dispersion Staining  
EPA Method 600/M4-82-020

\*\*\*\*\* RESULTS \*\*\*\*\*

Lab Date	Lab I.D. #	Sample Description	Asbestos Type	%
CORONADO SHORES Coronado, California # DFH-387 December 1, 1989				
1780 Avenida Del Mundo				
12-1-89	26913	White sprayed-on acoustical ceiling, # F2:MIC:1	Chrysotile Amphibole	ND ND
12-1-89	26914	White sprayed-on acoustical ceiling, # F2:MIC:2	Chrysotile Amphibole	ND ND
1750 Avenida Del Mundo				
12-1-89	26915	White sprayed-on acoustical ceiling, # F1:MIC:3	Chrysotile Amphibole	ND ND
12-1-89	26916	White sprayed-on acoustical ceiling,	Chrysotile Amphibole	ND ND

1820 Avenida Del Mundo

12-1-89	26919	White sprayed-on acoustical ceiling, # FB:MIC:7	Chrysotile Amphibole	ND ND
12-1-89	26920	White sprayed-on acoustical ceiling, # F1:MIC:8	Chrysotile Amphibole	ND ND

ND = no asbestos detected, method of limit detection is 1% .

Amphibole asbestos includes amosite, crocidolite, anthophyllite, tremolite, and actinolite.

This test report relates only to the items tested.

NOTE: Tile, vinyl, foam, plastic and fine powder samples may contain asbestos fibers of such small dimensions that fibers may not be detected by PLM. If greater certainty is required, more sensitive analytical methods such as X-Ray Diffraction, Transmission Electron Microscopy, and Scanning Electron Microscopy are recommended.

Design For Health, Inc. appreciates the opportunity to provide these services.

Sincerely,



Kabir Shefa  
Director of Technical Services